

EUR 4524 e

COMMISSION OF THE EUROPEAN COMMUNITIES

T U R B I N A

**A CODE FOR PREDICTING THE PERFORMANCE OF
POWER PLANTS OPERATING WITH SUPERHEATED
OR SATURATED STEAM CYCLES**

by

**E. BABORSKY (Politecnico di Milano, Istituto di Fisica Tecnica)
and
A. ENDRIZZI (Euratom)**

1970



**Joint Nuclear Research Center
Ispra Establishment - Italy**

Scientific Data Processing Center - CETIS

LEGAL NOTICE

This document was prepared under the sponsorship of the Commission of the European Communities.

Neither the Commission of the European Communities, its contractors nor any person acting on their behalf :

make any warranty or representation, express or implied, with respect to the accuracy, completeness or usefulness of the information contained in this document, or that the use of any information, apparatus, method or process disclosed in this document may not infringe privately owned rights; or

assume any liability with respect to the use of, or for damages resulting from the use of any information, apparatus, method or process disclosed in this document.

This report is on sale at the addresses listed on cover page 4

at the price of FF 5.60

FB 50.—

DM 3.70

Lit. 620.—

Fl. 3.60

When ordering, please quote the EUR number and the title, which are indicated on the cover of each report.

Printed by SMEETS, Brussels
Luxembourg, September 1970

This document was reproduced on the basis of the best available copy.

EUR 4524 e

TURBINA - A CODE FOR PREDICTING THE PERFORMANCE OF POWER PLANTS OPERATING WITH SUPERHEATED OR SATURATED STEAM CYCLES by E. BABORSKY (Politecnico di Milano, Istituto di Fisica Tecnica) and A. ENDRIZZI (Euratom)

Commission of the European Communities
Joint Nuclear Research Center - Ispra Establishment (Italy)
Scientific Data Processing Center - CETIS
Luxembourg, September 1970 - 32 Pages - 19 Figures - FB 50,—

Given throttle steam conditions, flow, feedwater temperature, condenser pressure, and if required, the reheater or separator pressure, the code calculates the arrangement of preheaters, the turbine-generator efficiency, and all the variables of thermodynamic interest.

EUR 4524 e

TURBINA - A CODE FOR PREDICTING THE PERFORMANCE OF POWER PLANTS OPERATING WITH SUPERHEATED OR SATURATED STEAM CYCLES by E. BABORSKY (Politecnico di Milano, Istituto di Fisica Tecnica) and A. ENDRIZZI (Euratom)

Commission of the European Communities
Joint Nuclear Research Center - Ispra Establishment (Italy)
Scientific Data Processing Center - CETIS
Luxembourg, September 1970 - 32 Pages - 19 Figures - FB 50,—

Given throttle steam conditions, flow, feedwater temperature, condenser pressure, and if required, the reheater or separator pressure, the code calculates the arrangement of preheaters, the turbine-generator efficiency, and all the variables of thermodynamic interest.

The possible steam cycle designs are :

- a) saturated with moisture removal stages
- b) saturated with moisture separator
- c) saturated with separator and live steam reheater
- d) superheated
- e) superheated with reheater.

The code has been tested on five existing steam power plants, constructed by different firms; the deviations between the real efficiency and the figure calculated by the code are less than $2^{\circ}/\infty$.

The possible steam cycle designs are :

- a) saturated with moisture removal stages
- b) saturated with moisture separator
- c) saturated with separator and live steam reheater
- d) superheated
- e) superheated with reheater.

The code has been tested on five existing steam power plants, constructed by different firms; the deviations between the real efficiency and the figure calculated by the code are less than $2^{\circ}/\infty$.

EUR 4524 e

COMMISSION OF THE EUROPEAN COMMUNITIES

T U R B I N A

**A CODE FOR PREDICTING THE PERFORMANCE OF
POWER PLANTS OPERATING WITH SUPERHEATED
OR SATURATED STEAM CYCLES**

by

**E. BABORSKY (Politecnico di Milano, Istituto di Fisica Tecnica)
and
A. ENDRIZZI (Euratom)**

1970



**Joint Nuclear Research Center
Ispra Establishment - Italy
Scientific Data Processing Center - CETIS**

ABSTRACT

Given throttle steam conditions, flow, feedwater temperature, condenser pressure, and if required, the reheater or separator pressure, the code calculates the arrangement of preheaters, the turbine-generator efficiency, and all the variables of thermodynamic interest.

The possible steam cycle designs are :

- a) saturated with moisture removal stages
- b) saturated with moisture separator
- c) saturated with separator and live steam reheater
- d) superheated
- e) superheated with reheater.

The code has been tested on five existing steam power plants, constructed by different firms; the deviations between the real efficiency and the figure calculated by the code are less than 2°/oo.

KEYWORDS

STEAM
FLUID FLOW
WATER
TEMPERATURE
CONDENSERS
PRESSURE
TURBINES
GENERATORS
THERMODYNAMICS
NUMERICALS

CONTENTS

INTRODUCTION

1. GENERAL REMARKS

- 1.1 Data
- 1.2 Preheaters and degasifier
- 1.3 Low pressure preheaters and moisture removal stages
- 1.4 Moisture separator
- 1.5 Reheater
- 1.6 Heat balance
- 1.7 Efficiency; net power
- 1.8 Assumptions

2. HOW TO USE THE CODE

- 2.1 Input
- 2.2 Calculated variables
- 2.3 Output
- 2.4 Routines of the thermodynamic properties of steam and water

3. SAMPLE CALCULATIONS

REFERENCES

INTRODUCTION *)

A code is presented for predicting the performance of steam power plants operating with various steam cycles arrangements, on the basis of the minimum number of given design parameters.

A detailed knowledge of the procedures to design the power plant is not required.

The experience and the high performance level gained by the companies constructing large steam turbine-generators, guarantees that the performances of new power plants can be predicted accurately on the basis of the knowledge of existing designs. This consideration led "GENERAL ELECTRIC Co." to the "Method for predicting the performance of steam turbine generators" (1), (2) which has been followed in this paper.

1. GENERAL REMARKS

1.1 Data

A minimum number of design parameters are required:

- a) throttle steam pressure and temperature (or moisture)
- b) steam flow
- c) reheater (or moisture separator) pressure, if any
- d) condenser pressure
- e) type of steam cycle

Various types of steam cycles have been considered:

- 1) saturated or low superheated steam cycle with moisture removal stages
- 2) saturated or low superheated steam cycle with moisture separator and moisture removal stages
- 3) saturated or low superheated steam cycle with separator, live steam reheater, and moisture removal stages
- 4) superheated steam cycle without reheater
- 5) superheated steam cycle with reheater.

*) Manuscript received on 15 June 1970

Fig.1 illustrates the possible steam cycle arrangements.

1.2 Preheaters and degasifier

The arrangement of preheaters, degasifier condenser, and feed-water pumps is presented in fig.2 and fig.3 .

The flow diagram shown in fig.2 is used in the case of superheated and/or reheated steam cycle (type 4 and 5); the diagram described in fig.3 is adopted in the case of saturated or low superheated steam cycle (type 1, 2, 3).

The degasifier's pressure is supposed to be a linear function of the throttle steam pressure.

Fig.4 shows the design parameters of a typical preheater.

Pinch points and pressure drops are standard figures; the feed-water temperature rise is less than 30°C. This condition determines the number of preheaters. As a first approach, the distribution of the extraction pressures is calculated assuming that each preheater raises the feedwater temperatures by the same amount. If the steam cycle design requires the separator or the reheater, the pressure range $p_1 - p_2$ (fig.5) is not clearly available for steam extraction. Pressure p_1 is assigned; p_2 is calculated by the code taking in account separator and/or reheater pressure drops. It is quite possible that feedwater temperature and reheater or separator pressure (input data) lead to special arrangements of the preheaters' distribution.

The following rules are always valid:

- a) if $p_1 < p < 0.8 \cdot p_2$ where p is the extraction pressure then
 $P = P_1$
 i.e. the steam extraction is placed at the exit of the high pressure turbine section.
- b) if a) is true and p is the highest extraction pressure

then $P = P_1$

and ΔT_H (fig.4) in the corresponding preheater is modified to obtain the assigned feedwater temperature.

In any case the degasifier extraction point is located in the low pressure turbine section.

1.3 Low pressure preheaters and moisture removal stages

If moisture removal stages are requested (steam cycle type 1, 2, 3), the standard configuration of fig.6 is adopted.

The pressures of the standard moisture removal stages are fixed. The intermediate moisture removal stages coincide with the steam extraction points of the low pressure preheaters. A change in the moisture removal pressures gives a negligible effect on the overall efficiency.

1.4 Separator

The efficiency of the separator is assumed to be 0.8 .

The condensing water is collected by the preheater which operates at the same pressure as the separator. Pressure drops are calculated by standard methods.

1.5 Reheater

Let us consider the steam cycle type 3 : the temperature difference between saturated reheater drains and reheated steam is 13.77°C. The drained water is sent to the preheater operating at the highest pressure.

The reheat temperature of steam cycle type 5 is equal to the throttle steam temperature. Pressure drops are standard.

1.6 Heat balance

Ref. [1] and [2] describe the method for calculating:

- the efficiencies of the turbine sections
- the expansion lines
- the efficiencies of the generator.

Ref. [3] contains the procedure for predicting:

- the extraction flows
- the flows through the turbine sections
- the gross power output
- the pumping power
- the mechanical and electric losses
- the overall efficiency of the plant.

1.7 Efficiency, net power

The efficiency is calculated as follows:

$$\frac{\text{gross power} - \text{pumping power} - (\text{mechanical and electrical losses})}{\text{steam generator flow} \cdot (\text{outlet enthalpy} - \text{inlet enthalpy}) + [(\text{reheater flow}) \cdot (\text{outlet enthalpy} - \text{inlet enthalpy})]^*)}$$

and

$$\text{gross power} = \sum_i (\text{flow through the turbine section} \cdot [\text{inlet enthalpy} - \text{outlet enthalpy}])_i$$

The overall efficiency is therefore defined as:

$$\frac{\text{net electric power output}}{\text{steam generator thermal power input}}$$

*) steam cycle type 5 only

1.8 Assumptions

With the aim of minimizing the number of input data, definite assumptions have been introduced. The procedure supplies a series of design parameters and chooses among many possible design arrangements. The most important assumptions are the following:

- conventionally cooled 3000 rpm generator
- isentropic efficiency of the pumps : 0.76
- change in enthalpy across the governing stage: 20 kcal/kg

Packing and valve steam leakages are not considered (the effect on the overall efficiency is estimated to be 1%).

2. HOW TO USE THE CODE

The code is written in FORTRAN IV language for IBM 360/65.
Total length: 96.000 bytes (2000 FORTRAN cards); 0.5 sec execution time.

The code is intended for iterative calculations such as techniques used to determine an optimum. For this reason a particularly simple data input form was chosen. The user writes his own "Main programme" and the calculation is executed by calling the following subroutines:

```
CALL SAT (P,T,FLOW, PEXHP, TFW, PC, NCYCLE, NCASE, NPRINT,
EFF, POWER, EEXHP, FLOWR)
```

for the steam cycle types 1, 2, 3 (saturated or low superheated steam)

or

```
CALL SUR (P,T, FLOW, PEXHP, TFW, PC, NCYCLE, NCASE, NPRINT,
EFF, POWER, EEXHP, FLOWR)
```

for the steam cycle types 4, 5 (superheated, reheated steam).

2.1 Data

P (kg/cm ²)	- admission steam pressure at the throttle valve, i.e. at the outlet of the steam generator
T (°C)	- steam temperature at the outlet of the steam generator
FLOW (ton/hour)	- steam flow at the outlet of the steam generator
PEXHP	- steam pressure at the outlet of the high pressure section of the turbine = pressure at the separator inlet (cycles 2,3) = pressure at the reheater inlet (cycle 5) PEXHP is meaningless in cycles 1 and 4
TFW (°C)	- feedwater temperature (steam generator inlet)
PC (kg/cm ²)	- condenser pressure
NCYCLE	- integer number : it defines the type of steam cycle
CALL SAT	<div style="display: inline-block; vertical-align: middle; font-size: 4em; line-height: 1;">{</div> <div style="display: inline-block; vertical-align: middle;"> <ul style="list-style-type: none"> - = 1 saturated or low superheated steam cycle with moisture removal stages - = 2 saturated or low superheated steam cycle with moisture removal stages + separator - = 3 saturated or low superheated steam cycle with moisture removal stages + separator + live steam reheater </div>
CALL SUR	<div style="display: inline-block; vertical-align: middle; font-size: 4em; line-height: 1;">{</div> <div style="display: inline-block; vertical-align: middle;"> <ul style="list-style-type: none"> - = 4 superheated steam cycle - = 5 superheated steam cycle + reheater (reheat temperature = admission temperature) </div>

The following parameters control the output:

NCASE	- integer number if NCASE = 0 no printed output is obtained if NCASE > 0 the results are printed (see output)
NPRINT	- integer number

= 0 normally
 if = 1 several intermediate results are
 printed for controlling the cal-
 culation procedure

2.2 Calculated variables

EFF	- efficiency of the plant (as defined above)
POWER (MWatt)	- net power output
EEXHP (kcal/kg)	- steam enthalpy at the output of the HP section of the turbine = enthalpy at the separator inlet for steam cycle types 3, 2 = enthalpy at the reheater inlet for steam cycle type 5 EEXHP is meaningless in cycles 1 and 4
FLOWR (ton/hour)	= steam flow at the reheater inlet (cycle type 5) = live steam flow required by the reheater (steam cycle type 3) FLOWR is meaningless in cycles 1, 2, 4.

The number of calculated variables, which appear in the calling sequence of the subroutine SAT or SUR, is small. This is because the user is supposed to be interested in efficiency and net power calculations only. Adopting a steam cycle type 5, the user is also informed about the reheater inlet steam enthalpy and flow, which may be useful for reheater design calculations.

However, by easy modifications it is possible to make any other interesting parameter available.

2.3 Output

If it is required by the user (NCASE > 0), a detailed description of the calculated plant is printed. Two tables contain all the design parameters (see fig.7 and fig.8). The first table gives the thermodynamic properties of steam at the extraction points. The operating conditions of each preheater and moisture removal stage (if any) are also described. The second table gives a picture of the performance of the other components and of the whole plant.

2.4 Subroutines of the thermodynamic properties of steam and water

Ref. [4] contains the formulation of the thermodynamic properties of steam and water (see also ref. [3]).

The properties appear in the form of FORTRAN functions and they are also available for independent purposes, not connected with the particular code "Turbina".

Below is a list of the functions used by this code.

Saturation region

ELSAT(T)	saturated liquid enthalpy
EVSAT(T)	saturated steam enthalpy
SLSAT(T)	saturated liquid entropy
SVSAT(T)	saturated steam entropy
PSAT(T)	saturation pressure
TLSAT(P)	saturation temperature
EX(P,S,E,X)	enthalpy and quality as functions of pressure and entropy
SX(P,E,S,X)	entropy and quality as functions of pressure and enthalpy

Liquid region

ELIQS(P,T)	liquid enthalpy
------------	-----------------

SLPT(P,T)	liquid entropy
VSLIQ(P,T)	liquid specific volume
TLIQS(E,P)	liquid temperature as a function of enthalpy and pressure

Superheat region

EVSUR(P,T)	steam enthalpy
SVSUR(P,T)	steam entropy
VSVAP(P,T)	steam specific volume
TVEP(E,P)	steam temperature as a function of enthalpy and pressure
ESURPS(P,S)	steam enthalpy as a function of pressure and entropy

The code carries out the calculations with the following units:

E	P	T	S	V
Kcal/kg	kg/cm ²	°C	kcal/kg°C	m ³ /kg

3. SAMPLE CALCULATIONS

The code "Turbina" has been tested on five existing steam turbine plants, constructed by different firms; the deviations between the real efficiency and the figure evaluated by the code are less than 2%.

Following the good results of these tests, the code has been used for predicting the performance of plants operating with various steam conditions. The results are plotted in figs. 10 to 19.

Certain data used in our designing have been fixed:

- net electric power output 250 MW
- condenser pressure 0,052 kg/cm²

and

- feedwater enthalpy = $K \cdot$ saturation enthalpy at throttle admission pressure

with $K = 0.65$ or $K = 0.75$

The resulting feedwater temperature as a function of the admission pressure appears in fig.9 .

The exit pressure of the HP turbine section (steam cycles 2, 3, 5) has been chosen as:


$$P_{EXHP} = 0.2 \cdot P$$

where P is the throttle admission pressure.


It should be noted that some curves drawn in figs. 10 - 19 are to be interpreted as extrapolations of the calculation procedures; they correspond to merely conceivable, but not technologically achievable designs of steam power plants, because the calculation procedure does not include any feasibility limit.

REFERENCES

- [1] SPENCER, COTTON, CANNON : "A Method for Predicting the Performance of Steam Turbine-Generators" General Electric Co., ASME 1963, 85, p.249
- [2] BAILY, COTTON, SPENCER: "Predicting the Performance of Large Steam Turbine Generators Operating with Saturated and Low Superheat Steam Condition", Large Steam Turbine Generator Department General Electric Co., Schenectady, N.Y., GER-2454 A
- [3] ENDRIZZI: "Un programma numerico per il calcolo delle prestazioni a carico nominale e parziale del gruppo turbina, alternatore, condensatore e preriscaldatori in centrali a ciclo di vapore con risurriscaldamento", EUR 3948.i CETIS, CCR Euratom
- [4] "VDI Wasserdampfatafeln", Springer-Verlag 1963



SUPERHEAT - PREHEATERS



SATURATED LOW SUPERHEAT-PREHEATERS




Fig. 3





Fig. 4

PREHEATER PRESSURE LOSS - PINCH POINTS





Fig. 5



MOISTURE REMOVAL STAGES LOW PRESSURE PREHEATERS (pressure Kg/cm²)

Fig. 6

*** PROGETTO N. 1 ***

PRERISC. NUMERO	PRESSIONE DI SPILL.	ENTALPIA DI SPILL.	TEMPERATURA USCITA ACQUA ALIM.	ENTALPIA USCITA ACQUA ALIM.	TEMPERATURA USCITA CONDENSA	PORTATA TON/ORA
1	0.25	595.12	61.20	61.30	63.97	26.905
2	0.31	532.54	89.17	89.29	66.70	28.903
3	2.12	559.23	117.11	117.43	94.67	30.160
4	4.32	706.55	145.06	145.92	122.61	31.502
5	0.14	740.55	177.12	181.63	173.02	30.981
6	10.23	736.50	206.37	212.66	182.62	36.646
7	34.00	504.92	235.37	244.82	212.37	51.430
8	43.20	705.95	250.69	260.16	242.37	26.658

Fig. 7

CALDAIA		ALTA PRESSIONE	RISORRISAL.	MEDIA E BASSA PR.	CONDENSATORE	GENERATORE
TIN = 250.59	TIN = 435.00	TIN = 272.13	TIN = 435.00	TIN = 33.26		
PIN = 167.00	PII = 170.00	PIN = 34.00	PIN = 30.60	PIN = 0.052		
EIN = 250.16	EII = 775.14	EIN = 694.93	EIN = 817.13	EIN = 553.24		
TOUT = 435.00	TOUT = 172.13	TOUT = 485.00	TOUT = 33.26			
POUT = 170.00	POUT = 34.00	POUT = 30.60	POUT = 0.05			
EOUT = 775.14	EOUT = 694.93	EOUT = 817.13	EOUT = 553.24			
PORTATA	PORTATA	PORTATA	PORTATA	PORTATA		
GS = 792.969	GR = 713.930		GC = 529.993			
CALORE SCAMBIATO	CALORE SCAMBIATO		CALORE SCAMBIATO			POTENZA ALLE PALE
QS = 474.199	QR = 101.451		QC = 319.792			WGROS = 262.270
RENDIMENTO	RENDIMENTO		RENDIMENTO			RENDIMENTO
ETAP = 34.0287	ETAC = 91.3433					ETAGE = 0.9934
POTENZA POMPA	POTENZA POMPE REFR. E COND.					PERDITA MECCANICA
HPUMP = 7.004	WR=0.476 HC=0.457					DWM = 1.053
	SUPERFICIE TUBI M2					PERDITA ELETTRICA
POTENZA DISPONIBILE = 249.933	RENDIMENTO = 0.4342		SC = 6319.9			DWE = 3.290

Fig. 7 bis

*** PROGETTO N. 2 ***

```

*****
* SPILLAM * PRESS. * ENTALP. * ENTALP. * DRENAG. * SPILLAM * TEMPER. * ENTALP. * TEMPER. * ENTALP. *
* NUMERO * SPILLAM * A MONTE * A VALLE * TON/ORA * TON/ORA * ACQUA AL * ACQUA AL * CONDENS * CONDENS *
*****
* 1 * 15.000 * 615.320 * 615.320 * 0.0 * 50.324 * 132.053 * 135.041 * 154.851 * 156.043 *
*****
* 2 * 5.400 * 601.129 * 601.129 * 0.0 * 62.134 * 149.301 * 151.189 * 122.455 * 122.929 *
*****
* 3 * 5.515 * 643.759 * 643.910 * 0.326 * 4.791 * ***** * ***** * ***** * ***** *
*****
* 4 * 2.109 * 624.355 * 625.452 * 1.147 * 51.433 * 116.905 * 118.314 * 91.005 * 91.009 *
*****
* 5 * 2.406 * 611.413 * 612.620 * 2.149 * 4.502 * ***** * ***** * ***** * ***** *
*****
* 6 * 0.705 * 599.423 * 594.205 * 6.687 * 32.091 * 85.455 * 86.723 * 38.895 * 39.783 *
*****
* 7 * 0.352 * 573.776 * 555.825 * 13.888 * 4.025 * ***** * ***** * ***** * ***** *
*****

```

Fig. 8


*** PROGETTO N 2 ***

```

*** ** ** ** **
* TEMP IN * PRES IN * ENTA IN * UMID IN * PORT IN * POTENZA *
*** ** ** ** *
* POMPA * 132.053 * 50.000 * 133.041 * * *1297.033 * 3.826 *
*** ** ** ** *
* GEN VAP * 134.332 * 75.000 * 137.577 * * *1297.033 * 720.506 *
*** ** ** ** *
* TURBINA * 174.281 * 50.000 * 155.205 * 0.000 *172.863 * 66.273 *
*** ** ** ** *
* SEPARAT * 107.365 * 15.000 * 115.620 * 0.108 *1122.552 * 102.231 *
*** ** ** ** *
* RISORSA * 106.514 * 14.751 * 133.413 * 0.018 *1020.271 * 124.214 *
*** ** ** ** *
* TURBINA * 198.723 * 13.373 * 704.452 * -0.082 *1020.271 * 191.687 *
*** ** ** ** *
* CONDENS * 55.250 * 0.000 * 553.639 * 0.126 * 732.000 * 466.369 *
*** ** ** ** *
* PERD ML * PERD EL * POTENZA DISPONIB. * RENDIMENTO TOTALE *
* SEPARAT * 1.250 * 1.360 * 249.000 * * 0.5470 *
*** ** ** ** *

```

Fig. 8 bis











Fig. 10
























NOTICE TO THE READER

All Euratom reports are announced, as and when they are issued, in the monthly periodical "**euro abstracts**", edited by the Centre for Information and Documentation (CID). For subscription (1 year : £ 6.17, US\$ 16.40) or free specimen copies please write to :

Handelsblatt GmbH
"euro abstracts"
Postfach 1102
D 4 Düsseldorf 1 (Germany)

or

**Office de vente des publications officielles
des Communautés européennes**
37, rue Glesener
Luxembourg



To disseminate knowledge is to disseminate prosperity — I mean general prosperity and not individual riches — and with prosperity disappears the greater part of the evil which is our heritage from darker times.

Alfred Nobel

SALES OFFICES

All reports published by the Commission of the European Communities are on sale at the offices listed below, at the prices given on the back of the front cover. When ordering, specify clearly the EUR number and the title of the report which are shown on the front cover.

SALES OFFICE FOR OFFICIAL PUBLICATIONS OF THE EUROPEAN COMMUNITIES

37, rue Glesener, Luxembourg (Compte chèque postal N° 191-90)

BELGIQUE - BELGIË

MONITEUR BELGE
Rue de Louvain 40-42 - 1000 Bruxelles
BELGISCH STAATSBAD
Leuvenseweg 40-42 - 1000 Brussel

DEUTSCHLAND

BUNDESANZEIGER
Postfach - 5000 Köln 1

FRANCE

SERVICE DE VENTE EN FRANCE
DES PUBLICATIONS DES
COMMUNAUTES EUROPEENNES
26, rue Desaix - 75 Paris 15°

ITALIA

LIBRERIA DELLO STATO
Piazza G. Verdi, 10 - 00198 Roma

LUXEMBOURG

OFFICE DE VENTE
DES PUBLICATIONS OFFICIELLES
DES COMMUNAUTES EUROPEENNES
37, rue Glesener - Luxembourg

NEDERLAND

STAATSDRUKKERIJ
Christoffel Plantijnstraat - Den Haag

UNITED KINGDOM

H. M. STATIONERY OFFICE
P.O. Box 569 - London S.E.1

Commission of the
European Communities
D.G. XIII - C.I.D.
29, rue Aldringer
Luxembourg

CDNA04524ENC