

# **EUR 4252 e**

**Part I**

**EUROPEAN ATOMIC ENERGY COMMUNITY - EURATOM**

## **HDP 2 - A DIGITAL PROGRAM CALCULATING THE SURFACES AND THE EFFICIENCIES OF A HEAT EXCHANGER COUPLED WITH A TURBINE AT NOMINAL POWER AND AT PART LOAD**

Part I: Description of the code version HD 2 calculating  
the nominal power characteristics

by

**W. BALZ, C. BONA and S. GECHELIN**

**1969**



**ORGEL Program**

**Joint Nuclear Research Center  
Ispra Establishment - Italy**

**ORGEL Project  
and  
Scientific Data Processing Center - CETIS**

## LEGAL NOTICE

This document was prepared under the sponsorship of the Commission of the European Communities.

Neither the Commission of the European Communities, its contractors nor any person acting on their behalf :

Make any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this document, or that the use of any information, apparatus, method, or process disclosed in this document may not infringe privately owned rights; or

Assume any liability with respect to the use of, or for damages resulting from the use of any information, apparatus, method or process disclosed in this document.

This report is on sale at the addresses listed on cover page 4

at the price of FF 8.50	FB 85.—	DM 6.80	Lit. 1 060	Fl. 6.20
-------------------------	---------	---------	------------	----------

**When ordering, please quote the EUR number and the title, which are indicated on the cover of each report.**

Printed by Guyot, s.a.  
Brussels, April 1969

This document was reproduced on the basis of the best available copy.

## **EUR 4252 e**

### **Part I**

HDP 2 - A DIGITAL PROGRAM CALCULATING THE SURFACES AND THE EFFICIENCIES OF A HEAT EXCHANGER COUPLED WITH A TURBINE AT NOMINAL POWER AND AT PART LOAD

Part I : Description of the code version HD 2 calculating the nominal power characteristics by W. BALZ, C. BONA and S. GECCHÉLIN

European Atomic Energy Community - EURATOM

ORGEL Program

Joint Nuclear Research Center - Ispra Establishment (Italy)

ORGEL Project and Scientific Data Processing Center - CÉTIS

Luxembourg, April 1969 - 38 Pages - 8 Figures - FB 85

The code HDP 2 is a digital program calculating the surfaces and the efficiencies of a heat exchanger coupled with a turbine at nominal power and at part load.

Steam cycles with or without reheating by the primary coolant may be treated. Different arrangements of the reheater section of the heat exchanger

---

## **EUR 4252 e**

### **Part I**

HDP 2 - A DIGITAL PROGRAM CALCULATING THE SURFACES AND THE EFFICIENCIES OF A HEAT EXCHANGER COUPLED WITH A TURBINE AT NOMINAL POWER AND AT PART LOAD

Part I : Description of the code version HD 2 calculating the nominal power characteristics by W. BALZ, C. BONA and S. GECCHÉLIN

European Atomic Energy Community - EURATOM

ORGEL Program

Joint Nuclear Research Center - Ispra Establishment (Italy)

ORGEL Project and Scientific Data Processing Center - CÉTIS

Luxembourg, April 1969 - 38 Pages - 8 Figures - FB 85

The code HDP 2 is a digital program calculating the surfaces and the efficiencies of a heat exchanger coupled with a turbine at nominal power and at part load.

Steam cycles with or without reheating by the primary coolant may be treated. Different arrangements of the reheater section of the heat exchanger

are possible :

- in series with the superheater,
- in parallel with the superheater,
- in parallel with the superheater, boiler and economizer.

The heat exchanger may be of the drum boiler or Benson boiler type. The primary coolant which in the actual code version may be OM 2 or HB 40 is assumed to flow on the shell side in counterflow to the steam or water.

This report is the first part of the complete code description. It describes the code version HD 2 which treats the design calculations.

are possible :

- in series with the superheater,
- in parallel with the superheater,
- in parallel with the superheater, boiler and economizer.

The heat exchanger may be of the drum boiler or Benson boiler type. The primary coolant which in the actual code version may be OM 2 or HB 40 is assumed to flow on the shell side in counterflow to the steam or water.

This report is the first part of the complete code description. It describes the code version HD 2 which treats the design calculations.

# **EUR 4252 e**

Part I

EUROPEAN ATOMIC ENERGY COMMUNITY - EURATOM

## **HDP 2 - A DIGITAL PROGRAM CALCULATING THE SURFACES AND THE EFFICIENCIES OF A HEAT EXCHANGER COUPLED WITH A TURBINE AT NOMINAL POWER AND AT PART LOAD**

Part I: Description of the code version HD 2 calculating  
the nominal power characteristics

by

W. BALZ, C. BONA and S. GECHELIN

1969



**ORGEL Program**

**Joint Nuclear Research Center  
Ispra Establishment - Italy**

**ORGEL Project  
and  
Scientific Data Processing Center - CETIS**

## ABSTRACT

The code HDP 2 is a digital program calculating the surfaces and the efficiencies of a heat exchanger coupled with a turbine at nominal power and at part load.

Steam cycles with or without reheating by the primary coolant may be treated. Different arrangements of the reheater section of the heat exchanger are possible :

- in series with the superheater,
- in parallel with the superheater,
- in parallel with the superheater, boiler and economizer.

The heat exchanger may be of the drum boiler or Benson boiler type. The primary coolant which in the actual code version may be OM 2 or HB 40 is assumed to flow on the shell side in counterflow to the steam or water.

This report is the first part of the complete code description. It describes the code version HD 2 which treats the design calculations.

## KEYWORDS

H-CODES  
EFFICIENCY  
HEAT EXCHANGERS  
TURBINES

## PREFACE

The code HDP 2 is described in two parts which will be published separately. In Part I, the code version HD 2 is described which determines the characteristics of the steam plant at nominal power. The version HD 2 is operational and tested.

The final code version HDP 2 which treats also the part load behaviour of the plant is actually being tested and will be published later.

TABLE OF CONTENTS

	Page
1. <u>Basic features of the code</u>	5
2. <u>Mathematical formulation</u>	6
2.1.        QT-diagram	7
2.2.        Turbine preheater arrangement	10
2.3.        Heat exchanger	15
2.4.        Physical properties	17
3. <u>Program description</u>	19
<u>List of references</u>	30

APPENDIX I	: Symbols
APPENDIX II	: Numerical example
APPENDIX III	: How to use the code



1. Basic features of the code

HD 2 is a code calculating the steady state characteristics of a steam plant at full power. Main results of a calculation are the surfaces of each heat exchanger section (eco, boiler, superheater, reheater) which are needed to produce a given gross electric power. Besides this a detailed description of the thermodynamic conditions in the turbine and of the preheater system is given.

Different steam cycles may be treated :

- cycles with or without reheating by primary coolant
- reheater in series with the superheater (the primary coolant passes first the superheater then the reheater)
- reheater is in parallel with the superheater
- reheater is in parallel with the superheater, boiler and economizer

The possible reheater arrangements are shown in fig. 1.

The heat exchanger may be of the drum boiler type or Benson boiler type in which the primary coolant and water or steam are in counterflow. Water and steam are assumed to flow on the tube side.

The heat transfer coefficients are calculated from the given tube geometry for each section (diameter, wall thickness) and from the velocities which are also given for the tube and shell side. As in the code geometrical details of the heat exchanger are not considered, it is assumed that the given velocities may be obtained by a suitable arrangement of the tubes (number of tubes, pitch) or by baffles.

The correlations programmed for the heat transfer on the shell side of the tube correspond to cross flow as it may be assumed for helically wounded tubes or vertical tubes with baffles.

The pressure drop in the heat exchanger and in the circuit is taken into account as a fraction of the local pressure which is given for each section of the heat exchanger and of the circuit.

The physical properties of two primary coolants are programmed actually : OM2 and HB40 with a high boiler content to be specified.

The water/steam properties foreseen in the code are valid over the whole range of interest.

It should be mentioned that the code may easily be adapted to other heat exchanger configurations or primary coolants by changing the corresponding subroutines.

For studies which refer only to the turbine-preheater arrangement an additional code version (HD 2 - TP) was developed. The mathematical formulation is the same as for HD 2 with exception of the QT-diagram and the heat exchanger which are not considered. Data resulting from the QT-diagram are input values.

## 2. Mathematical formulation

The calculation procedure may be subdivided in three blocks for each of which the mathematical formulation is briefly described. For variables which are input or output values of the code the same symbols are taken as in the code (see APPENDIX I).

2.1. QT-diagram

In fig. 2 a QT-diagram is shown for a steam cycle with reheating, the reheater being in series with the superheater. It shows the temperature evolution on the primary and secondary side in function of the heat exchanged. The code is made such that the primary temperatures at the heat exchanger inlet and outlet, the steam pressure at the turbing inlet and the pinch points are input values. The feed water temperature and the reheating temperature are determined from heat balances. The total heat exchanged is given by :

$$QE + QB + QR + QS = QP \quad (1)$$

Introducing the mass flows and enthalpies, equation (1) may be written :

$$GS \int (ESOE - ESIE) + (ESOB - ESIB) + (ESOS - ESIS) \int + BETA.GS (ESOR - ESIR) = GP (EPIS - EPOE) \quad (2)$$

where BETA is the ratio of the mass flow through the reheater and superheater.

Assuming that no heat losses occur between two heat exchanger sections it is :

$$ESOE = ESIB$$

$$ESOB = ESIS$$

Then equation (2) becomes :

$$(ESOS - ESIE) + BETA.(ESOR - ESIR) = \frac{GP}{GS} (EPIS - EPOE) \quad (2a)$$

The enthalpies on the water/steam side depend from the local pressure and temperature. For the primary coolant the pressure influence is negligible. As it had been said before, the pressure drop is not calculated by the code but is imposed as a given fraction of the local pressure. For example, the pressure drop in the economizer results from :

$$\begin{aligned} \text{PSOE} &= \text{DPECO} \cdot \text{PSIE} \\ \Delta p_{\text{ECO}} &= \text{PSIE} - \text{PSOE} = (1 - \text{DPECO}) \cdot \text{PSIE} \end{aligned}$$

the DP-values are given for each section of the heat exchanger and of the steam circuit. In this way, starting from the pressure at the turbine inlet which is an input value the pressures at the boundary between two sections are calculated.

As the calculation of the local pressure is independent from the QT-diagram, the heat balances are written in the following, only as a function of the temperatures.

Equation (2a) becomes then :

$$\begin{aligned} \text{ESOS}(\text{TSOS}) - \text{ESIE}(\text{TSIE}) + \text{BETA} \cdot \left[ \text{ESOR}(\text{TSOR}) - \text{ESIR}(\text{TSIR}) \right] \\ = \frac{\text{GP}}{\text{GS}} \left[ \text{EPIS}(\text{TPIS}) - \text{EPOE}(\text{TPOE}) \right] \quad (3) \end{aligned}$$

the unknowns in eq. (3) are TSIE, TSOR and GP/GS. BETA depends from the preheater arrangement. It is equal to 1 in case there is no HP-preheater. TSIR results from the steam conditions at the HP-turbine outlet.

For the temperature TSIE another heat balance may be made. The heat exchanged in the economizer is equal to :

$$\text{GP} \left[ \text{EPIE}(\text{TPIE}) - \text{EPOE}(\text{TPOE}) \right] = \text{GS} \left[ \text{ESOE}(\text{TSOE}) - \text{ESIE}(\text{TSIE}) \right]$$

one gets :

$$\text{ESIE}(\text{TSIE}) = \frac{\text{GP}}{\text{GS}} \left[ \text{EPOE}(\text{TPOE}) - \text{EPIE}(\text{TPIE}) \right] + \text{ESOE}(\text{TSOE}) \quad (4)$$

The temperature TSOE may be calculated from the local pressure if one assumes that the water leaving the economizer is just saturated.

The temperature TPIE is obtained from

$$TPIE = TSOE + PINCHE$$

The temperature TSOR results from a heat balance made for the superheater :

$$\begin{aligned} GP \sqrt{EPIS(TPIS) - EPOS(TPOS)} &= GS \sqrt{ESOS(TSOS) - ESIS(TSIS)} \\ EPOS(TPOS) &= \frac{GS}{GP} \sqrt{ESIS(TSIS) - ESOS(TSOS)} + EPIS(TPIS) \end{aligned} \quad (5)$$

Neglecting again heat losses between two sections, it is :

$$EPOS = EPIR \quad \text{or} \quad TPOS = TPIR$$

and finally one gets :

$$TSOR = TPOS - PINCHR$$

From equations (3), (4), and (5) all unknowns may be determined. As the temperature TSIR and the mass flow ratio BETA are results of the turbine and preheater calculation an iterative calculation procedure becomes necessary.

For the other reheater arrangements the calculation of the QT-diagram becomes simpler (see fig. 3). In case there is no reheater equation (5) is not needed.

With the reheater in parallel the temperature TSOR results directly from the pinch point condition. As shown in fig.3 for this arrangement it was assumed that the primary coolant leaves the superheater and the reheater with the same temperature.

For the reheater being in parallel to eco, boiler and superheater two independent QT-diagrams exist : one for the eco, boiler and superheater, the other for the reheater. From the first one results the final feed water temperature as in the case without reheater. For the QT-diagram of the reheater all temperatures are known. Again the assumption was made that the primary coolant leaves the economizer and reheater with the same temperature.

## 2.2. Turbine preheater arrangement

The turbine-preheater arrangement is shown in fig. 4.

### 2.2.1. Preheaters

The final feed water temperature TSIE results from the QT-diagram, the condenser temperature is an input value.

The feed water temperature at the inlet of the first preheater (in the sense of the feed flow) may be higher by a value DTC than the condenser temperature. DTC which is an input datum represents a temperature difference resulting from an external heat source like a generator or moderator cooling system.

It is possible to impose the number of preheaters (NPR) or the feed water temperature rise in one preheater (DTPR). In both cases the temperature rise is equal for each preheater.

In case temperature rise is fixed, the number of preheaters results from :

$$NPR = \frac{TSIE - (TC + DTC)}{DTPR}$$

Taking the nearest integer for NPR the effective temperature rise is slightly different. The number of preheaters being established the feed water temperature after each preheater is easily determined.

To determine the pressure of the bled steam condensing in the preheater a pinch (PINCH) is assumed by which the saturation temperature of the condensing steam must be higher than the feed water temperature after the preheater :

$$TPR = TF + PINCH$$

A QT-diagram for a preheater is shown in fig. 5.

Due to the pressure drop between preheater and turbine tapping the pressure at the turbine is :

$$PTUR = \frac{PPR}{DPTPR}$$


where DPTPR is a given value which is constant for all bleeding lines of the same turbine cylinder.

For the degasifier the pinch point is zero as steam and feed water are in direct contact. The degasifier is placed at a temperature of about 150°C.

After all bled steam tapping pressures are fixed the corresponding steam enthalpies may be determined from the turbine expansion (see chapter 2.2.2.) and the bled steam mass flows can be calculated. For sake of simplicity it was assumed that the condensated bled steam is pumped back into the main feed line directly after each preheater (see fig. 4). The temperature after the mixing of both mass flows is considered as the feed water temperature after a preheater.

If in a point of a steam tapping the steam moisture exceeds a certain value, a moisture reduction is foreseen. For the bled steam mass flow calculation it is assumed that the extracted water is taken for preheating.

For the general case of a turbine tapping with water extraction the bled steam mass flow is obtained from a heat balance which is illustrated in the figure below.



The water extraction is symbolized by a drum in which the steam enters with a certain steam quality  $X_1$ . The steam goes back to the turbine with a new quality  $X_2$ , the mass flow being reduced by  $GPR$ .

The mass flow going to the preheater may be subdivided in a water and a steam flow which are :

$$GW = G(1 - X_1) - (G - GPR)(1 - X_2)$$

$$GST = G \cdot X_1 - (G - GPR) X_2$$

From a heat balance made for the reheater for which it is assumed that the bled steam condensate is pumped into the main feed line behind each preheater one gets :

$$GPR = G \cdot \frac{EOUT - EIN + (X_2 - X_1) \left[ \sqrt{EVSAT(PTUR) - ELSAT(PTUR)} \right]}{X_2 \cdot EVSAT(PTUR) + (1-X_2) ELSAT(PTUR) - EIN}$$

$PTUR$  is the pressure in the turbine tapping point.



The moisture reduction expressed as  $X1 - X2$  is obtained from

$$X2 = X1 + \text{ETAEXT} (1 - X1)$$

where  $\text{ETAEXT}$  is the separation efficiency.

### 2.2.2. Turbine

Several turbine cylinders are possible. An eventual reheater must be placed between the first and the second one. Between two cylinders a pressure drop and heat loss may occur which has to be specified in the input.

If from the preheater calculation a bled steam tapping pressure was found which is close to the final pressure of a cylinder the latter is automatically taken equal to the tapping pressure.

The turbine expansion starts from the inlet steam conditions which take into account eventual pressure or heat losses between heat exchanger and turbine. The expansion line is determined from subexpansions which take place between two subsequent pressures. These pressures may be bled steam pressures or cylinder end pressures (see fig. 6). With the turbine expansion efficiency which is an input value for each cylinder the enthalpy after each subexpansion is calculated.<sup>(\*)</sup> Before each subexpansion it is checked whether the steam moisture doesn't exceed a maximum admissible value. Otherwise a water extraction is foreseen (see chapter 2.2.1.).

After the expansion line is established and the bled steam mass flows are determined, the following values are calculated.

-----  
(\*) For wet steam the efficiency is reduced by  $\text{DETA}$  (see App.I)  
for each percent of average moisture.

- Expansion work

$$STOT = \sum_{j=1}^{NZONE} \sum_{i=1}^{NE(J)} (HTUR(J,i) - HFE(J,i)) \cdot GT(J,i) \quad \text{[kcal/s]}$$

where

NZONE = number of cylinders

NE(J) = number of subexpansions in the J<sup>th</sup> cylinder

HTUR(J,i) = enthalpy at the beginning of the i<sup>th</sup> expansion in the J<sup>th</sup> cylinder [kcal/kg]

HFE(J,i) = enthalpy at the end of the i<sup>th</sup> expansion in the J<sup>th</sup> cylinder [kcal/kg]

GT(J,i) = corresponding mass flow [kg/s]

- Turbine outlet loss

$$OUTLOS = \frac{1}{427} \cdot \frac{VTO^2}{2g} \cdot GT(NZONE, NE(ZONE)) \quad \text{[kcal/s]}$$

- Feed pumping power

The pump head is given by the degasifier pressure, the pressure drop between pump and turbine and the turbine admission pressure.

$$WPP(1) = \frac{(PFD - PD) \cdot G1(ND) \cdot VSLIQ(PD, TD)}{ETAPP(1) \cdot ETAMO(1)} \cdot \frac{10^4}{101,98} \quad \text{[kW]}$$

where :

PFP = pressure behind the pump [ata]

PD = degasifier pressure [ata]

G1(ND) = mass flow through the feed pump [kg/s]

ND = degasifier index

- Extraction pumping power

The pump head is determined by the degasifier pressure, the condenser pressure and by the pressure drop in the feed line.

$$WPP(2) = \frac{(PCP - PC) \cdot G1(NPR + 1) \cdot VS LIQ(PC, TC)}{ETAPP(2) \cdot ETAMO(2)} \cdot \frac{10^4}{101,98} \quad \boxed{\text{ kW }}$$

the symbols have a similar meaning like in the formula for the feed pump.

- Thermodynamic efficiency

$$ETATH = \frac{STOT - OUTLOS}{HETOT}$$

where

$$HETOT = \text{total heat exchanged} \quad \boxed{\text{ kcal/s }}$$

- Steam cycle gross efficiency

$$ETASB = ETATH \cdot ETAMC \cdot ETAGEN$$

- Steam cycle net efficiency

$$ETASN = ETASB - \frac{WPP(1) + WPP(2)}{HETOT} \cdot \frac{1}{4,185}$$

2.3. Heat exchanger

The code is made so that no detailed information about the heat exchanger geometry is needed (or must be determined by the code itself). Only some basic assumptions had to be made concerning the heat transfer calculations :

- the primary and secondary medium are in counterflow
- the primary coolant flows on the shell side
- the tube arrangement is so that in all sections cross flow may be assumed.

The velocities on the shell and tube side were taken as input values assuming that they may be realized by an appropriate choice of the tube pitch, or of the baffle distance or by a

suitable tube number. In case of a Benson boiler the velocity on the tube side only for one section (eco or superheater) can be given. The other is calculated as resulting from a constant tube number and tube geometry.

Between two heat exchanger sections a pressure drop may be specified to take into account a possible multi-block arrangement.

The heat transfer correlations used in the code are :

a) - Primary-shell side

$$Nu = 0.32 \cdot Re^{0.61} \cdot Pr^{0.31}$$

b) - Economizer-tube side

$$Nu = 0.024 \cdot Re^{0.8} \cdot Pr^{0.37}$$

c) - Boiler-tube side

$$\alpha = 40537 \cdot \varphi^{0.72} \cdot p^{0.24} \cdot \frac{1}{4185} \quad \left[ \text{kcal/sm}^2 \text{grd} \right]$$

where

$$\begin{aligned} \varphi &= \text{heat flux} \quad \left[ \text{MW/m}^2 \right] \\ p &= \text{pressure} \quad \left[ \text{ata} \right] \end{aligned}$$

d) - Superheater-tube side

$$Nu = 0.023 \cdot Re^{0.8} \cdot Pr^{0.4}$$

The subroutines calculating the heat transfer coefficients may easily be exchanged.

The overall heat transfer coefficient is calculated from the following correlation :

$$\frac{1}{ALFA} = \frac{RE}{RI} \cdot \frac{1}{ALFAI} + RE \cdot \frac{\ln RE/RI}{\lambda} + \frac{1}{ALFAE} + HF$$

where

RE, RI = external and internal tube radius  
HF = fouling factor

Finally the (external) tube surface becomes :

$$SURF = Q / (ALFA \cdot DTLB)$$

where

DTLB = logarithmic temperature difference

## 2.4. Physical properties

### 2.4.1. Primary coolant

Two types of coolant are available in the code :  
OM2 and HB40 with a variable high boiler content.  
All properties were taken from ref. [1].

#### 2.4.1.1. OM2

Density [g/cm<sup>3</sup>]

$$\rho = 1.1141 + 12.5 \times 10^{-4} (HB) - 7.7 \times 10^{-4} t$$

here and in the following correlations the dimensions are :

$$[t] = \text{°C} \quad [HB] = \%$$

Viscosity  $\left[ \frac{p}{t} \right]$

$$\ln \mu = -9.1406 - 2.132 \times 10^{-3}(\text{HB}) - 2.302 \times 10^{-4}(\text{HB})^2 + \frac{2.0979 \times 10^3 + 3.739(\text{HB}) + 0.4068(\text{HB})^2}{t}$$

Specific heat  $\left[ \frac{\text{J}}{\text{g}^\circ\text{C}} \right]$

$$C_p = 1.53 + 2.7 \times 10^{-3} t$$

From this the enthalpy difference  $\left[ \frac{\text{J}}{\text{kg}} \right]$  referred to 100°C was obtained :

$$i - i_{100} = 1.53t + 1.35 \times 10^{-3}t^2 - 166.5$$

Thermal conductivity  $\left[ \frac{\text{W}}{\text{cm}^\circ\text{C}} \right]$

$$\lambda = 1.58 \times 10^{-3} + (t + 273)10^{-7} \left[ -7.89 + 1.65 \log(\text{HB}) \right]$$

#### 2.4.1.2. HB40

Density  $\left[ \frac{\text{g}}{\text{cm}^3} \right]$

$$\rho = 1.038 + 5.897 \times 10^{-4}(\text{HB}) + \left[ -7.887 \times 10^{-4} + 5.162 \times 10^{-6}(\text{HB}) \right] t$$

Viscosity  $\left[ \frac{p}{t} \right]$

$$\ln \mu = -9.4957 + 2.6869 \times 10^{-2}(\text{HB}) + \left[ 2.29608 \times 10^3 - 1.08805 \times 10^1(\text{HB}) \right] \frac{1}{t+273}$$

Specific heat  $\left[ \frac{\text{J}}{\text{g}^\circ\text{C}} \right]$

$$C_p = 1.448 + 1.594 \times 10^{-3}(\text{HB}) + \left[ 3.741 - 2.67(\text{HB}) \right] 10^{-3} t$$

Thermal conductivity  $\left[ \frac{\text{W}}{\text{cm}^\circ\text{C}} \right]$

$$\lambda = 1.239 \times 10^{-3} + 4.326 \times 10^{-6} (\text{HB}) - 5.063 \times 10^{-7} \cdot t - 3.85 \times 10^{-9} \cdot t(\text{HB})$$

#### 2.4.2. Water/Steam

The water/steam properties correspond to those given in "VDI-Wasserdampfatafeln".


### 3. Program description

In the following chapter block-diagrams of the main program and the more important subroutines are given. Each block describes a set of equations. The different operations are explained.

Table 1 gives a list of the functions developed for the calculation of the steam and water characteristics at different temperatures and pressures.

The program version HD2 - TP which treats the turbine preheater arrangement independently from the heat exchanger uses the same subroutines except those regarding the QT-diagram and the surface computation.

MAIN PROGRAM





Computes pressures, enthalpies, temperatures on primary and secondary side. These values are derived from input data, assuming an arbitrary power to be exchanged

SUBROUTINE  
Q T D I A G

Assumes tentative values for:  
 $BETA = \frac{\text{sec.mass flow in reheater}}{\text{sec.mass flow in superh.}}$   
GS = secondary mass flow  
TSIR = reheater secondary inlet temperature

Iterates on GS until the exchanged heat by the primary in the boiler, superheater and reheater is = to the heat requested to bring a GS (kg/sec) flow from saturated liquid (PSIB, TSIB) to steam (PSOS, TSOS), and to reheat BTA .GS (kg/sec) of steam from PSIR = PFE(1).DPTR, TSIR to PSOR = PSIR + DPRH, TSOR

Computes second.temp.at the inlet of economizer (TSIE), and calculates the preheater arrangement, the turbine expansion, and new values for PSIR, PSOR, TSIR, ESIR, BETA


CALL PRERIS

NO  
does BETA coincide with the assumed value?  
YES

do ESIR and PSIR coincide with the assumed values?  
NO

RETURN

SUBROUTINE  
P R E R I S




- Input variables of subroutine TURBEX are :

PA, TA, HA, SA, VA, XA, PS, ETA<sup>(\*)</sup>, DETA

- Output variables of subroutine TURBEX are :


TS, HS, SS, VS, XS, PX1, TX1, HX1, SX1, VX1



Values on the liquid curve and on the saturated steam curve at PS are indicated with a letter followed by L or V, respectively. (For ex. : HL means enthalpy of saturated liquid, HV means enthalpy of saturated steam).

(\*) ETA is the expansion efficiency in the dry zone, DETA is the reduction in % of ETA for % of average humidity.

SUBROUTINE  
TURBEX



SUBROUTINE MOISTE :

Calculates characteristics of the steam after a water extraction according to the following formula :

$$\begin{aligned} X &= XIN + ETA \cdot (1 - XIN) \\ S &= X \cdot SV + (1 - X) \cdot SL \\ H &= X \cdot HV + (1 - X) \cdot HL \\ V &= X \cdot VSV + (1 - X) \cdot VSL \end{aligned}$$

- Input variables :

T = Temperature of steam  
XIN = Steam quality before water extraction  
ETA = Extraction efficiency

- Output variables :

X = Steam quality after water extraction  
S = Steam entropy after water extraction  
H = Steam enthalpy after water extraction  
V = Steam specific volume after water extraction

- Functions used :

SV = SVSAT(T) Entropy of saturated steam at T  
SL = SLSAT(T) Entropy of saturated water at T  
HV = EVSAT(T) Enthalpy of saturated steam at T  
HL = ELSAT(T) Enthalpy of saturated water at T  
P = PSAT(T) Saturation pressure at T  
VSV = VSVAP(P,T) Specific volume of saturated steam at T  
VSL = VSLIQ(P,T) Specific volume of saturated water at T

SUBROUTINE PREHEA

Calculates the bled steam mass flow G' according to the formula :

$$G' = \frac{EOUT - EIN + (X2 - X1) \cdot (EV - EL)}{X2 \cdot EV + (1 - X2) \cdot EL - EIN} \cdot G$$

- Input variables :

G            Water mass flow at the preheater inlet  
EOUT        Enthalpy at the preheater outlet  
EIN        Enthalpy at the preheater inlet  
P            Pressure at the preheater outlet  
PTUR        Pressure of steam at the turbine tapping  
TTUR        Temperature of steam at the turbine tapping  
HTUR        Enthalpy of steam at the turbine tapping  
X1        Steam quality at the turbine tapping  
X2        Steam quality after water extraction (When no  
          extraction X2 = X1)

- Output variables :

G'            Bled steam mass flow (including eventual waterextract.)  
T1            Feed water temperature after preheater before mixing  
          with bled steam condensate

- Functions used :

EV        =    EVSAT(TTUR)        Enthalpy of saturated steam at TTUR  
EL        =    ELSATT(TTUR)        Enthalpy of saturated water at TTUR  
T1        =    TLIQS(P,T)        Water temperature at P, T

SUBROUTINE DEFZON

Compares the pressure at the point where tapping occurs with the pressure corresponding to the end of each cylinder given as input data (PFE), changing the latter in case both values differ less than 10%.

SUBROUTINE ECON

Calculates the heat transfer coefficient and the surface of the economizer with the formulas :

$$ALFAE = \frac{1}{\frac{RE}{Ri} \cdot \frac{1}{ALFASE} + \frac{RE}{\lambda} \cdot \ln \frac{RE}{RI} + \frac{1}{ALFAPE} + HF1} \quad \text{and}$$

$$SURFE = QE / (ALFAE \cdot DTLE)$$

where :

RE            External tube radius  
Ri            Internal tube radius  
 $\lambda$             thermal conductivity of the tube material

- Input variables

QE            Heat to be exchanged in the economizer  
TPIE          Primary side inlet temperature  
TPOE          Primary side outlet temperature  
TSIE          Secondary side inlet temperature  
TSOE          Secondary side outlet temperature  
PSIE          Secondary side inlet pressure  
PSOE          Secondary side outlet pressure  
WPECO        Velocity of primary fluid  
WSECO        Velocity of secondary fluid  
DECO          Tube diameter  
SPECO        Tube wall thickness  
HF1           Fouling factor in the economizer

- Output variables :

SURFE        Surface of the economizer  
ALFAE        Overall heat transfer coefficient  
DTLE        Logarithmic temperature difference  
TPME        Primary side average temperature  
TSME        Secondary side average temperature

ALFAPE Heat transfer coefficient between primary side  
and the wall

ALFASE Heat transfer coefficient between secondary side  
and the wall

- Functions used

ECO1 Calculates the heat transfer coefficient between  
the primary side and the wall according to the  
formula :

$$Nu = 0.32 \cdot Re^{0.61} \cdot Pr^{0.31}$$

where

Re = Reynolds number  
Pr = Prandtl number  
Nu = Nusselt number

Physical characteristics of the fluid are calcu-  
lated at  $TPME = (TPIE + TPOE)/2$

ECO2 Performsthe same calculations as ECO1, between the  
wall and the secondary side, according to the  
formula :

$$Nu = 0.024 \cdot Re^{0.8} \cdot Pr^{0.37}$$

Physical characteristics of the fluid are calcu-  
lated at  $TSME = (TSIE + TSOE)/2$



SUBROUTINE BOILER

Calculates the heat transfer coefficient and the surface of the boiler.

The subroutine uses the same formulas as the subroutine ECON with exception of that for the secondary heat transfer coefficient, which is :

$$BBOIL2 = 40537 \cdot F^{0.72} \cdot P^{0.24} / 4185$$

where

$$\begin{aligned} BBOIL2 &= \text{heat transfer coefficient} \quad \text{kcal/s m}^2 \text{grd} \\ F &= \text{heat flux on the inner tube surface} \quad \left[ \frac{\text{MW}}{\text{m}^2} \right] \\ p &= \text{water/steam pressure} \quad \left[ \text{ata} \right] \end{aligned}$$

The other symbols used for the input and output variables correspond to those used for the subroutine ECON. The primary heat transfer coefficient is calculated by the function ABOIL 1 which uses the same formula as ECO 1. Different formulas were defined to be able to exchange the formulas for the different heat exchanger sections independently.

SUBROUTINE SURRIS

Calculates the heat transfer coefficient and the surface of the superheater.

The only difference in comparison with the subroutine ECON is the formula used for the secondary heat transfer coefficient which is :

$$Nu = 0.023 \cdot Re^{0.8} \cdot Pr^{0.4}$$

This formula is evaluated by the function SUR 2. The primary heat transfer coefficient is calculated by the function SUR 1 which in the actual code version is equal to ECO 1.

SUBROUTINE RISURR

Does the same calculations for the reheater. In the actual version it is identical to the subroutine SURRIS.

LIST OF REFERENCES

- [1] R.Lopes Cardozo, J.F. Terrien  
"Comparaison des deux réfrigérants organiques :  
OM2, HB40".  
Rapport EUR (to be published)

Acknowledgements : The authors wish to thank Mr. M. LECLOUX for his cooperation in testing the code.

TABLE 1





Functions used for steam and water properties

---

ELIQS(P,T)	water enthalpy at $P(\text{kg}/\text{cm}^2)$ , $T(^{\circ}\text{C})$
-----	
ELSAT(T)	saturated water enthalpy (kcal/kg) at $T(^{\circ}\text{C})$
-----	
EVSAT(T)	saturated steam enthalpy (kcal/kg) at $T(^{\circ}\text{C})$
-----	
EVSUR(P,T)	superheated steam enthalpy (kcal/kg) at $P(\text{kg}/\text{cm}^2)$ , $T(^{\circ}\text{C})$
-----	
TLIQS(E,P)	water temperature ( $^{\circ}\text{C}$ ) at $E(\text{kcal}/\text{kg})$ , $P(\text{kg}/\text{cm}^2)$
-----	
TLSAT(P)	saturation temperature ( $^{\circ}\text{C}$ ) at $P(\text{kg}/\text{cm}^2)$
-----	
TEVSUR(E,P)	steam temperature ( $^{\circ}\text{C}$ ) at $E(\text{kcal}/\text{kg})$ , $P(\text{kg}/\text{cm}^2)$
-----	
TVSUR(P,S)	steam temperature ( $^{\circ}\text{C}$ ) at $P(\text{kg}/\text{cm}^2)$ , $S(\text{kcal}/\text{kg}/^{\circ}\text{C})$
-----	
PSAT(T)	saturation pressure ( $\text{kg}/\text{cm}^2$ ) at $T(^{\circ}\text{C})$
-----	
SLSAT(T)	saturated water entropy (kcal/kg/ $^{\circ}\text{C}$ ) at $T(^{\circ}\text{C})$
-----	
SVSAT(T)	superheated steam entropy (kcal/kg/ $^{\circ}\text{C}$ ) at $T(^{\circ}\text{C})$
-----	
SVSUR(P,T)	superheated steam entropy (kcal/kg/ $^{\circ}\text{C}$ ) at $P(\text{kg}/\text{cm}^2)$ , $T(^{\circ}\text{C})$

---

---

Without reheaterWith reheater in series with the superheaterWith reheater in parallel to the superheaterWith reheater in parallel to Eco, boiler and superheater

QT- Diagram

( Reheater in series )







Fig. 3  
GO-2283




Without reheat




Reheater in parallel to the superheater




Reheater in parallel to Eco, Boiler and Superheater





QT - diagram for a preheater





APPENDIX 1 - SYMBOLS

The nomenclature used for the input and output of the code is based on the following system :

A.I. Data referring to the QT-diagram

- the first letter indicates the physical property
- the second letter indicates if the variable refers to the primary or secondary side
- the third letter indicates the point to which the physical property refers
- the fourth indicates the zone to which the value is referred

for example :

TPIE

means :

Temperature on the PPrimary side at the Economizer Inlet

The letters used have the following signification :

First letter

E = enthalpy	kcal/kg
G = mass flow	kg/s
P = pressure	ata
S = entropy	kcal/kg
T = temperature	°C
V = specific volume	m <sup>3</sup> /kg
X = steam quality	--

Second letter

P = primary side  
S = secondary side

Third letter

I = inlet  
O = outlet

(in the sense of flow)

Fourth letter

B = boiler  
E = economizer  
R = reheater  
S = superheater

A.II. For the turbine the nomenclature used is the following :

First letter : indicates the physical property as  
mentioned above

Second letter : indicates the beginning or the end of  
a subexpansion

Third letter : E = subexpansion  
SAT = refers to the saturation condition

A.III. For the preheaters the letters PR are added to the physical  
properties

A.IV. Other symbols

Symbols not corresponding to this system are :

Symbol	Meaning	Dimension
POWER	gross electric power	MW
NEXC	number of heat exchangers	--
OPTION	indicates the heat exchanger arrangement	--
	1 = no preheater	
	2 = reheater and superheater in series	
	3 = reheater and superheater in parallel	
	4 = reheater in parallel to eco, boiler and superheater	
ITYPE	indicates the primary coolant	--
	1 = OM2	
	2 = HB40	
PHB	percentage of high boilers	
PS	steam pressure at turbine admission valve	ata
PC	condenser pressure	ata
NZONE	number of turbine cylinders (max.5)	--
PFE(i)	pressure at outlet of cylinder (i)	ata
VTO	turbine outlet velocity	m/s
ETA	turbine expansion efficiency(=ETAD)	--
DETA	efficiency correction factor for steam moisture	--
ETAW	ETA corrected for steam moisture	--
ETAEXT	water extraction efficiency	--
XEXTR	steam quality below which moisture reduction is foreseen	--
ETAMO(i)	pump motor efficiency	--
	i = 1 feed pump	
	i = 2 extraction pump	
ETAPP(i)	pump efficiency	--
ETAMC	turbine/generator mechanical effic.	--
ETAGEN	generator electric efficiency	--
PFPP	pressure behind feed pump	at
PCP	pressure behind extraction pump	at

Symbol	Meaning	Dimension
GP	total primary flow per HE	kg/s
GPS	eco, boiler, superheater primary flow per HE	" "
GPR	reheater primary flow per HE	" "
GS	live steam flow per HE	" "
BETA	ratio reheater to live steam flow	--
DPTR	pressure drop pipes HP-turbine-reheater	--
DPPR	" " for one preheater	kg/cm <sup>2</sup>
DPSA	" " pipes superheater-turbine	--
DPSH	" " superheater	--
DPRH	" " reheater	--
DPBS	" " between boiler-superh.	--
DPBO	" " boiler	--
DPEB	" " between eco-boiler	--
DPEC	" " eco	--
DPTPR	" " bleeding pipe	--
DPZONA(i)	pressure loss at turbine cylinder(i) inlet	
DHZONA(i)	enthalpy " " " " " "	kcal/kg
DTPR	temperature rise over one preheater	°C
DTC	feed water temperature rise by external source	°C
NPR	number of preheaters	--
NUPRE	" " " if NUPR=0 the number of preheaters is calculated from DTPR	--
NDG	number of preheater which is the degasifier	--
NS(i)	number of bled tappings in turbine cylinder (i)	--
EF	feed water enthalpy after a preheater	kcal/kg
T1	feed water temperature behind a preheater before the bled steam condensate is added	--
PD	degasifier pressure	ata
TD	degasifier temperature	°C
PINCH	preheater pinch point	

Symbol	Meaning	Dimension
PINCHE	pinch at economizer outlet	°C
PINCHS	pinch at superheater outlet	°C
PINCHR	pinch at reheater outlet	°C
WPECO	primary coolant velocity in eco	m/s
WPEVA	" " " " boiler	m/s
WPRSUR	" " " "reheater	m/s
WPSUR	" " " superheater	m/s
WSECO	water velocity in eco	m/s
WRSUR	steam velocity in reheater	m/s
WSSUR	" " in superheater	m/s
DECO	tube diameter in eco	m
DEVA	" " " boiler	m
DRSUR	" " " reheater	m
DSUR	" " " superheater	m
SPECO	tube wall thickness in eco	m
SPEVA	" " " " boiler	m
SPRSUR	" " " " reheater	m
SPSUR	" " " " superheater	m
HF1	fouling factor in the economizer	$\frac{\text{sec } ^\circ\text{C m}^2}{\text{kcal}}$
HF2	" " " " boiler	"
HF3	" " " " reheater	"
HF4	" " " " superheater	"
NUMBER	arbitrary number to identify the case	--
PRINT	a positive value must be taken in case intermediate results are wanted	--

APPENDIX II - NUMERICAL EXAMPLE

In the following the listing is given of a case for which first the complete HD2 calculation was made. Then with the results from the QT-diagram calculation the same case was repeated with the HD2 - TP version.

The steam mass flows obtained from the HD2 calculation correspond to the given electric power (100 MW). In case of the HD2 - TP calculation they refer to 1 kg of live steam.

\*\*\* INPUT DATA BENSON

\* CASE N = 1 OPTION = 3 \*\*\*

68/11/13

18.02.44

GROSS ELECT. POWER (MWATT)

POWER = 100.00

NUMBER OF EXCHANGERS

NEXC = 4

TEMPERATURES (C)

TPIS = 370.000  
TPOE = 290.000  
TSIR = 224.100

PINCH POINTS (C)

PINCHE = 10.000  
PINCHR = 10.000  
PINCHS = 10.000  
PINCH = 2.000

PRESSURES (KG/CM2) (\*)

PS = 74.000  
PC = 0.043  
PFE(1) = 23.000  
PFE(2) = 0.048

PRESS. LOSSES (KG/CM2) (\*\*)

DPZONA(1) = 0.950  
DPZONA(2) = 0.925  
DPZONA(3) = 0.900

DPTR = 0.943  
DPPR = 0.200  
DPSA = 0.970  
DPSH = 0.950  
DPRH = 0.960  
DPBS = 1.000  
DPBO = 0.950  
DPEB = 1.000  
DPEC = 0.850  
DPTPR = 0.950, 0.950,

ENTHALPY LOSSES (KCAL/KG)

DHZONA(1) = 0.0  
DHZONA(2) = 0.0  
DHZONA(3) = 0.0

EXPANSION CHARACTERISTICS

N. OF CYLINDERS 2  
ETA(1) = 0.83 DETA(1) = 1.00 ETAEXT(1) = 0.20 XEXTR(1) = 0.96  
ETA(2) = 0.88 DETA(2) = 1.00 ETAEXT(2) = 0.20 XEXTR(2) = 0.96

EFFICIENCIES

FEED PUMP EFFICIENCY = 0.800 CONDEN. PUMP EFFICIENCY = 0.800  
MOTOR EFF. (FEED PUMP) = 0.700 MOTOR EFF. (CONDEN. PUMP) = 0.900  
TURB./GEN. MECH. EFF. = 0.990 GENER. ELECTRIC EFFIC. = 0.988

FOULING FACT. (M2\*SEC\*C/KCAL)

ECON. = 0.0 BOIL. = 0.0 RHEAT. = 0.0 SHEAT. = 0.0

OUTLET SPEED (M/SEC)

VTO = 250.00

ADDITIONAL PREHEATING (C)

DTC = 0.0

PERCENTAGE OF HIGH BOILER

PHB = 30.00

GEOMET. CHARACTERIST. OF HEAT EXCHANGER

WPE = 1.30 WPB = 1.30 WPR = 2.50 WPS = 1.30  
WSE = 1.00 WSR = 35.00 WSS = 23.83  
DEC = 0.0200 DBO = 0.0200 DRE = 0.0200 DSU = 0.0200  
SPE = 0.00150 SPB = 0.00150 SPR = 0.00150 SPS = 0.00150

OUTPUT HD 2 COMPLETE VERSION

\* THESE DATA MAY BE CHANGED BY THE PROGRAM  
\*\* RELATIVE VALUES



\*\*\*\*\*

\*\*\* QT DIAGRAM \*\*\*

TEMPERATURE (C) , ENTHALPY (KCAL/KG) , PRESSURE (KG/CM\*\*2)

GP = 358.275 (KG/SEC) GS = 26.942 (KG/SEC) BETA = 1.00 THERM. POW. = 69.374 (MWATT)  
 GPS= 163.649 (KG/SEC) GPR= 194.623 (KG/SEC)

QE = 3494.4 (KCAL/SEC) QB = 9192.1 (KCAL/SEC) QR = 2110.6 (KCAL/SEC) QS = 1777.0 (KCAL/SEC)

\*\*\* PRIMARY SIDE \*\*\*

\*\*\* SECONDARY SIDE \*\*\*

TPIS = 370.00	EPIS = 139.61	PPIS = 5.00	*	TSOS = 360.00	ESOS = 724.85	PSOS = 76.29
TPOS = 351.85	EPOS = 128.75	PPOS = 5.00	*	TSIS = 293.88	ESIS = 658.89	PSIS = 80.30
TPIR = 370.00	EPIR = 139.61	PPIR = 5.00	*	TSOR = 360.00	ESOR = 754.07	PSOR = 20.82
TPOR = 351.85	EPOR = 128.75	PPOR = 5.00	*	TSIR = 224.10	ESIR = 675.73	PSIR = 21.69
TPIB = 351.85	EPIB = 128.75	PPIB = 5.00	*	TSOB = 293.88	ESOB = 658.89	PSOB = 80.30
TPOB = 307.47	EPOB = 103.10	PPOB = 5.00	*	TSIB = 297.47	ESIB = 317.71	PSIB = 84.53
TPIE = 307.47	EPIE = 103.10	PPIE = 5.00	*	TSOE = 297.47	ESOE = 317.71	PSOE = 84.53
TPOE = 290.00	EPQE = 93.34	PPQE = 5.00	*	TSIE = 184.55	ESIE = 188.01	PSIE = 99.45

\*\*\*\*\*

\*\*\* PREHEATER \*\*\*

PSIE = 99.447 PFP = 99.647 PD = 4.345 PCP = 4.745 PC = 0.043 (KG/CM\*\*2)  
 TSIE = 184.554 TD = 145.917 TC = 30.006 (C)  
 DTPR = 38.637 (C) NPR = 4 NDG = 2  
 NS( 1) = 0  
 NS( 2) = 4

GPR (KG/S)	GPR/GS	PPR(KG/CM2)	TPR (C)	G (KG/S)	G/GS	EF(KCAL/KG)	T1 (C)
7.454	0.069	11.361	184.554	107.768	1.000	188.006	184.301
6.871	0.064	4.345	145.917	100.314	0.931	147.764	145.789
6.379	0.059	1.426	107.280	93.443	0.867	107.452	107.040
7.062	0.066	0.327	68.643	87.064	0.808	68.644	68.349

\*\*\*\*\*

\*\*\*\*\*

\*\*\* TURBINE EXPANSION \*\*\*

\*\*\* CYLINDER N. = 1 , EXPAN. N. = 1 , STEAM FLOW = 107.768 (KG/S) \*\*\*

PIE = 70.300	POE = 23.000	(KG/CM2)
TIE = 354.768	TOE = 226.658	(C)
HIE = 724.846	HOE = 675.730	(KCAL/KG)
SIE = 1.497	SOE = 1.517	(KCAL/KG/C)
VIE = 0.036	VOE = 0.091	(M**3/KG)
XIE = 1.000	XOE = 1.000	
ETAD = 0.83	ETAW = *****	

\*\*\*\*\*

\*\*\* CYLINDER N. = 2 , EXPAN. N. = 1 , STEAM FLOW = 107.768 (KG/S) \*\*\*

PIE = 19.260	POE = 12.485	(KG/CM2)
TIE = 358.562	TOE = 304.809	(C)
HIE = 754.059	HOE = 729.581	(KCAL/KG)
SIE = 1.675	SOE = 1.631	(KCAL/KG/C)
VIE = 0.149	VOE = 0.211	(M**3/KG)
XIE = 1.000	XOE = 1.000	
ETAD = 0.83	ETAW = *****	

\*\*\*\*\*

\*\*\* CYLINDER N. = 2 , EXPAN. N. = 2 , STEAM FLOW = 100.314 (KG/S) \*\*\*

PIE = 12.435	POE = 4.574	(KG/CM2)
TIE = 304.809	TOE = 195.916	(C)
HIE = 729.581	HOE = 680.911	(KCAL/KG)
SIE = 1.631	SOE = 1.695	(KCAL/KG/C)
VIE = 0.211	VOE = 0.471	(M**3/KG)
XIE = 1.000	XOE = 1.000	
ETAD = 0.83	ETAW = *****	

\*\*\*\*\*

\*\*\* CYLINDER N. = 2 , EXPAN. N. = 3 , STEAM FLOW = 93.443 (KG/S) \*\*\*

PIE = 4.574	PESAT = 1.867	POE = 1.501	(KG/CM2)
TIE = 195.916	TESAT = 117.460	TOE = 110.810	(C)
HIE = 680.911	HESAT = 644.965	HOE = 637.096	(KCAL/KG)
SIE = 1.695	SESAT = 1.708	SOE = 1.711	(KCAL/KG/C)
VIE = 0.471	VESAT = 0.962	VOE = 1.167	(M**3/KG)

XIE = 1.000      XESAT = 1.00      XOE = 0.99  
ETAD = 0.880      ETAW = 0.875

\*\*\*\*\*

\*\*\* CYLINDER N. = 2 , EXPAN. N. = 4 , STEAM FLOW = 87.064 (KG/S) \*\*\*

PIE = 1.501	PUE = 0.344	(KG/CM2)
TIE = 110.810	TOE = 71.836	(C)
HIE = 637.096	HOE = 590.395	(KCAL/KG)
SIE = 1.711	SOE = 1.736	(KCAL/KG/C)
VIE = 1.167	VOE = 4.434	(M**3/KG)
XIE = 0.989	XOE = 0.933	
ETAD = 0.88	ETAW = 0.84	

\*\*\* WATER EXTRACTION AT P = 0.344 , T = 71.836 , GEXT = 1.242 (KG/SEC) \*\*\*

X1 = 0.9325	X2 = 0.9460
H1 = 590.40	H2 = 597.90
S1 = 1.74	S2 = 1.76

\*\*\*\*\*

\*\*\* CYLINDER N. = 2 , EXPAN. N. = 5 , STEAM FLOW = 80.002 (KG/S) \*\*\*

PIE = 0.344	PUE = 0.048	(KG/CM2)
TIE = 71.836	TOE = 31.855	(C)
HIE = 597.897	HOE = 547.303	(KCAL/KG)
SIE = 1.758	SOE = 1.800	(KCAL/KG/C)
VIE = 4.434	VOE = 26.533	(M**3/KG)
XIE = 0.946	XOE = 0.890	
ETAD = 0.88	ETAW = 0.80	

\*\*\*\*\*

\*\*\* EFFICIENCIES \*\*\*

** THERMODYNAMIC EFFICIENCY	** ETATH =	0.36843	**
** STEAM CYCLE GROSS EFFIC.	** ETASB =	0.36036	**
** STEAM CYCLE NET EFFIC.	** ETASN =	0.35508	**
** TOT. PUMP. POWER/GROSS ELECT. POWER	** NUS1 =	0.01466	**
** TOT. PUMP. POWER/THERMAL POWER	** NUS2 =	0.00528	**
** FEED PUMPING POWER (KW)	** =	1414.64	**
** CONDENSER PUMPING POWER (KW)	** =	51.45	**
** OUTLET LOSS	** =	0.00900	**
** TOTAL SURFACE (M**2)	** =	1279.05	**

\*\* HEAT TRANSFER COEFFICIENTS AND SURFACES \*\*

TYPE OF COOLANT = QM2

	ECONOM.		BOILER		REHEATER		SUPERHEATER	
AVER. TEMP. ON PRIMARY SIDE	298.74	C	329.66	C	360.93	C	360.93	C
AVER. TEMP. ON SECONDARY SIDE	241.01	C	295.68	C	292.05	C	326.94	C
LOGARITHM. DT	40.52	C	27.30	C	46.22	C	27.30	C
PRIM. ALFA	0.615	KCAL/S/M2/C	0.649	KCAL/S/M2/C	1.015	KCAL/S/M2/C	0.681	KCAL/S/M2/C
SEC. ALFA	2.401	KCAL/S/M2/C	3.970	KCAL/S/M2/C	0.310	KCAL/S/M2/C	0.990	KCAL/S/M2/C
TOTAL ALFA	0.439	KCAL/S/M2/C	0.500	KCAL/S/M2/C	0.202	KCAL/S/M2/C	0.355	KCAL/S/M2/C
FOULING	0.0	S*M2*C/KCAL	0.0	S*M2*C/KCAL	0.0	S*M2*C/KCAL	0.0	S*M2*C/KCAL
EXCHANG. HEAT SURFACE	3494.4	KCAL/S	9192.1	KCAL/S	2110.6	KCAL/S	1777.0	KCAL/S
PRIMARY SPEED	1.30	M/S	1.30	M/S	2.50	M/S	1.30	M/S
SECONDARY SPEED	1.00	M/S	*****	M/S	35.00	M/S	23.83	M/S
PRIMARY PRANDTL NUMBER	1.362437E 01		1.135048E 01		9.646044E 00		9.646044E 00	
SEC. PRANDTL NO	8.132502E-01				1.017570E 00		1.308266E 00	
PRIMARY REYNOLD NUMBER	3.240351E 04		3.977285E 04		9.189494E 04		4.778534E 04	
SEC. REYNOLD NO	1.272645E 05				2.545542E 05		6.513883E 05	
PRIMARY NUSSELT NUMBER	4.057407E 02		4.344619E 02		6.885017E 02		4.620269E 02	
SEC. NUSSELT NO	2.696245E 02				4.890764E 02		1.146762E 03	

\*\*\* INPUT DATA \*\*\*

68/11/14

14.58.47

CASE N = 1                    OPTION = 3

TEMPERATURES (C)

TSIE = 184.554  
TSOR = 360.000  
TSIR = 224.100  
TSOS = 360.000  
PINCH = 2.000

PINCH POINT (C)

PRESSURES (KG/CM2) (\*)

PS = 74.000  
PC = 0.043  
PFE(1) = 23.000  
PFE(2) = 0.048

OUTPUT HD 2 - TP

PRESS. LOSSES(KG/CM2) (\*\*)

DPZONA(1) = 0.950  
DPZONA(2) = 0.925  
DPZONA(3) = 0.900

DPTR = 0.943  
DPPR = 0.200  
DPSA = 0.970  
DPSH = 0.950  
DPRH = 0.960  
DPBS = 1.000  
DPBO = 0.950  
DPEB = 1.000  
DPEC = 0.850  
DPTPR = 0.950, 0.950,

ENTHALPY LOSSES (KCAL/KG)

DHZONA(1) = 0.0  
DHZONA(2) = 0.0  
DHZONA(3) = 0.0

EXPANSION CHARACTERISTICS

N. OF CYLINDERS 2

ETA(1) = 0.83    DETA(1) = 1.00    ETAEXT(1) = 0.20    XEXTR(1) = 0.96  
ETA(2) = 0.88    DETA(2) = 1.00    ETAEXT(2) = 0.20    XEXTR(2) = 0.96

STEAM OUTLET SPEED (M/SEC)

VTO = 250.00

ADDITIONAL PREHEATING (C)

DTC = 0.0

EFFICIENCIES

FEED PUMP EFFICIENCY = 0.800                    CONDENS. PUMP EFFICIENCY = 0.800  
MOTOR EFF. (FEED PUMP) = 0.900                    MOTOR EFF. (CONDENS. PUMP) = 0.900  
TURB./GEN. MECH. EFF. = 0.990                    GENER. ELECTRIC EFFIC. = 0.988

\* THESE DATA MAY BE CHANGED BY THE PROGRAM  
\*\* RELATIVE VALUES

\*\*\*\*\*

TEMPERATURE (C) , ENTHALPY (KCAL/KG) , PRESSURE (KG/CM2)

GP = 1.000 (KG/SEC)

BETA = 1.000

\*\*\*\*\*

\*\*\* PREHEATER \*\*\*

PSIE = 99.447 PFP = 99.647 PD = 4.345 PCP = 4.745 PC = 0.043 (KG/CM\*\*2)

TSIE = 184.554 TD = 145.917 TC = 30.006 (C)

DTPR = 38.637 (C) NPR = 4 NDG = 2

NS(1) = 0

NS(2) = 4

GPR (KG/S)	GPR/GS	PPR(KG/CM2)	TPR (C)	G (KG/S)	G/GS	EF(KCAL/KG)	T1 (C)
0.069	0.059	11.861	184.554	1.000	1.000	187.987	194.282
0.064	0.064	4.345	145.917	0.931	0.931	147.764	145.789
0.059	0.059	1.426	107.280	0.867	0.867	107.453	107.040
0.065	0.065	0.327	68.643	0.808	0.808	68.644	68.352

\*\*\*\*\*







** THERMODYNAMIC EFFICIENCY	** ETATH =	0.36848	**
** STEAM CYCLE GROSS EFFIC.	** ETASB =	0.36742	**
** STEAM CYCLE NET EFFIC.	** ETASN =	0.35513	**
** TOT. PUMP. POWER/GROSS ELECT. POWER	** NUS1 =	0.01466	**
** TOT. PUMP. POWER/THERMAL POWER	** NUS2 =	0.00528	**
** FEED PUMPING POWER (KW)	** =	13.12718	**
** CONDENSER PUMPING POWER (KW)	** =	0.47778	**
** OUTLET LOSS	** =	0.00901	**

APPENDIX III - HOW TO USE THE CODECode characteristics

The program was written in FORTRAN IV for use with an IBM 360/65 computer. The execution time for one case is about 5".

Input preparation

Input is made according to the "namelist" format (1). An example is given in fig. AIII-1 for the code HD2 and in fig. AIII-2 for the version HD2-TP.

- data must be preceded by their name followed by an equal sign. Their order is trivial
- arrays are introduced by name without subscript; items are separated by commas
- data are separated by commas
- the list for each case must begin with "&CASE" punched in column 2 and end with "&END".
- several cases may run in sequence; only data which change must be introduced

In case a Benson boiler is calculated the velocities on the steam/water side for the economizer or for the superheater must be given.

-----  
(1) See IBM-System Reference Library - FORTRAN Language -  
FORM C28-6515-A

Sample input for HD2

```

PHB = 30., ITYPE = 1, NUPRE = 0,                                E END
.025, DRSUR = .025, SPECO = .002, SPEVA = .0026, SPRSUR = .0023, SPSUR = .0023,
=.T4, WSECO = 2.5, WSSUR = 0., WRSUR = 16.5, DECO = .0135, DEVA = .027, DSUR =
HF1 = .33, HF2 = .33, HF3 = .33, HF4 = .33, WPECO = 1., WPEVA = 1., WPSUR = .74, WPRSUR
ETAPP = 2#.8, ETAMO = 2#.9, ETAMC = .99, ETAGEN = .98, VTO = 250., DTC = 0.,
DPSH = .96, DPRH = .96, DPBS = .98, DPBO = .96, DPEB = 1., DPEC = .95, DPPR = .2,
DPZONA = .95, .975, 4#.9, DPTR = .95, DTPR = 30., DPTPR = 5#.95, DPSA = .97,
ETA = .83, .86, 3#0., ETAEXT = 5#0.2, XEXTR = 5#.96, NZONE = 2, DHZONA = 6#0.,
PINCHR = 10., PINCH = 2., PS = 74., PC = .04, PFE = 22., .044, 3#0., DETA = 5#1.,
NEXC = 4, TPIS = 370., TPOE = 290., TSIR = 220., PINCHE = 10., PINCHS = 10.,
E CASE NUMBER = 1, OPTION = 2, PRINT = -1, POWER = 170.,

```

Sample input for HD2-TP

ε CASE NUMBER = -1, ε END

VTO = 250., DTC = 3., HUPRE = 5.,

DPPR = 2., ETAPP = 5\*.8, ETAMO = 5\*.9, ETAMC = .99, ETAGEN = .98,

DPSH = .95, DPRH = .96, DPBS = .95, DPBO = .95, DPES = 1, DPEC = .95,

DHZONA = 6\*0, DPTR = .97, DPTR = 30, DPTPR = 5\*.95, DPSA = .97,

ETAEXT = 5\*.2, XEXTR = 5\*.97, NZONE = 3, DPZONA = .95, .945, 4\*.98,

PFE = 20., 3.5, .044, 0., 0., ETA = .83, .925, .85, 2\*0., DETA = 5\*1.,

TSOR = 360., TSIR = 210., TSOS = 360., PINCH = 2., PS = 72., PC = .04,

ε CASE NUMBER = 1, OPTION = 2, PRINT = -1, TSIE = 170.,




## NOTICE TO THE READER

All Euratom reports are announced, as and when they are issued, in the monthly periodical **EURATOM INFORMATION**, edited by the Centre for Information and Documentation (CID). For subscription (1 year: US\$ 15, £ 6.5) or free specimen copies please write to:

**Handelsblatt GmbH**  
**"Euratom Information"**  
**Postfach 1102**  
**D-4 Düsseldorf (Germany)**

or

**Centrale de vente des publications**  
**des Communautés européennes**  
**37, rue Glesener**  
**Luxembourg**



To disseminate knowledge is to disseminate prosperity — I mean general prosperity and not individual riches — and with prosperity disappears the greater part of the evil which is our heritage from darker times.

Alfred Nobel

## SALES OFFICES

All Euratom reports are on sale at the offices listed below, at the prices given on the back of the front cover (when ordering, specify clearly the EUR number and the title of the report, which are shown on the front cover).

### **CENTRALE DE VENTE DES PUBLICATIONS DES COMMUNAUTES EUROPEENNES**

37, rue Glesener, Luxembourg (Compte chèque postal N° 191-90)

#### **BELGIQUE — BELGIË**

MONITEUR BELGE  
40-42, rue de Louvain - Bruxelles  
BELGISCH STAATSBLAD  
Leuvenseweg 40-42 - Brussel

#### **LUXEMBOURG**

CENTRALE DE VENTE  
DES PUBLICATIONS DES  
COMMUNAUTES EUROPEENNES  
37, rue Glesener - Luxembourg

#### **DEUTSCHLAND**

BUNDESANZEIGER  
Postfach - Köln 1

#### **NEDERLAND**

STAATSDRUKKERIJ  
Christoffel Plantijnstraat - Den Haag

#### **FRANCE**

SERVICE DE VENTE EN FRANCE  
DES PUBLICATIONS DES  
COMMUNAUTES EUROPEENNES  
26, rue Desaix - Paris 15<sup>e</sup>

#### **ITALIA**

LIBRERIA DELLO STATO  
Piazza G. Verdi, 10 - Roma

#### **UNITED KINGDOM**

H. M. STATIONERY OFFICE  
P. O. Box 569 - London S.E.1

**EURATOM — C.I.D.**  
29, rue Aldringer  
L u x e m b o u r g

CDNA04252ENC